



CELEBRATING  
**40** YEARS  
 1982-2022



# Traxx SL System

Traxx SL flooring system to concrete surfaces

**Specification No: P4021**

**Dated: May 2020**

**Project & Address:**

---



---

**Certified Applicator:**

---

**Building Contractor:**

---

**Building Owner/Property Manager:**

---

## 1. Statement of Intent

- (a) This checklist is to be completed by both the Equus Applicator and the Building Contractor, as a step by step record of compliance with both the Equus Specification provided for the contract, and the requirements of the Manufacturers for Warranty purposes.
- (b) A copy of this checklist must be forwarded to the nearest Regional Office of Equus Industries Ltd. A Warranty will not be issued by Equus Industries Ltd. without a copy of this Checklist being filed.
- (c) A copy of this checklist should form part of the Contract Documentation filed with the Property Manager on job completion.

## 2. Areas Treated

The areas to which the Membrane is applied are detailed below, with reference to plans (where appropriate).

---



---



---

## 3. Sign Off

We confirm that all applicable processes listed in Section 4 have been correctly completed and that sign-off on each stage has been made by a person with the authority to do so.

For: \_\_\_\_\_ (Signature)  
 (Building Contractor)

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ (Name)

For: \_\_\_\_\_ (Signature)  
 (Equus Applicator)

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ (Name)

#### 4. Checklist And Method Statement

\* Denotes those processes which must be signed off by the Building Contractor as well.

No.	Process	Completed On	Building Contractor	Equus Contractor	Notes
1.*	All concrete surfaces shall be prepared with suitable methods to achieve a clean and porous surface. Check corresponding Specification for further instructions.				
2.	All surfaces shall be treated with Equus <b>Mosskill</b> solution (if required) to kill all moss/ mould spores and growths. Stipulated kill-times shall be observed.				
3.	All major imperfections shall be filled using: <ul style="list-style-type: none"> <li>• <b>Ready Rep Mortar</b> or</li> <li>• <b>ASOCRET BIS 5/40</b> or</li> <li>• <b>Chevaline Epistixx Mortar.</b></li> </ul>				
4.	All minor imperfections shall be filled using <b>Epar 801</b> .				
5.	The vertical faces of upstands associated with the <b>Traxx SL</b> floor shall be flushed out as required with <b>Epar 801</b> epoxy mortar, and then sealed with one (1) coat of <b>Chevaline Epistixx</b> , followed by two (2) coats of <b>Traxx SLT</b> applied at approximately 2 - 2.5 m <sup>2</sup> per litre per coat, incorporating 300 gsm chopped strand mat at construction transitions.				
6.	Apply one (1) coat of <b>Chevaline Epistixx</b> , mixed and applied by roller or brush at 8 – 10 m <sup>2</sup> per litre and allowed to cure overnight.				
7.	Apply one (1) coat of <b>Traxx SL</b> , mixed and diluted 10% with xylol for application by roller at 6 – 8 m <sup>2</sup> per litre. Allow to cure minimum 6 hours and not more than 24 hours.				
8.	Apply one (1) coat of <b>Traxx SL</b> , correctly mixed, by serrated trowel at 0.8 – 0.9 m <sup>2</sup> per litre. A porcupine roller shall be used for finishing, only where necessary. Allow to cure tack-free for approximately 8 hours.				
9.	All areas to receive a non-skid finish shall be clearly delineated by masking out and shall receive one (1) coat of <b>Colourcure 2 KFG NS</b> , applied by brush or roller at a spreading rate of 7-8 m <sup>2</sup> per litre.				
10.	The flooring system shall <u>not</u> be carried over any elastomeric sealant beads. All construction joints shall be correctly masked out and sealed with <b>Dymonic FC</b> , working in strict accordance with appropriate Manufacturer's procedures.				